## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rose Chapel Church Parsonage DATE 6-28-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION US 21 N TR Past Barkers Store on Harmon Dr. 1/4 mi on right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes | (✓) | No | ( ) | |
| Auto. Dishwasher | Yes | (✓) | No | ( ) | |
| Auto. Wash. Machine | Yes | (✓) | No | ( ) | |
| Site Suitable | Yes | (✓) | No | ( ) | |

Character & Porosity of Soil Cecil Fine Sandy Clay
Percolation Rate 80 min / inch
Topography 2 to 4% Slope
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area .7 acres



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Paul Frye

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: Grade lot & pipe Gutters so water will not run into area where the lines are installed.

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 6-28-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold