11175

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

37841

OWNER OR CONTRACTOR Fast Track Inc. DATE 9-28-90 PERMIT NO. _____

PHONE: Busin[illegible] Home _____

LOCATION I-77 N Tl on 21 beside Rose chapel Chr

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other Conven. Store with Food Stand no Seats 800gal/day Projected

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Clayey
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	45
Auto. Wash. Machine	Yes ( )	No ( )	Topography	2 to 6%
Site Suitable	Yes ( )	No ( )	Depth to Water Table	10' +
			Rock or other impervious formations	None

Lot Area _____


_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

1000 gal grease Trap

Size of Tank 1500 gal ST. Gals.

Nitrification Field:
No. of Lines 6
Sq. Ft. 2340 Linear Ft. 780
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)



Plot of System

Installed by Harry Reep

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: Excess Risers to be Provided over tide on S.T. & Grease Trap brought up to Surface

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 9-28-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold