IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 7-14-98 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N TR on Rt 2171 TL on Rt 2172

S. R. No. _____


SUBDIVISION NAME Danbury Forest LOT NO. 16 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	LSBZ
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min +
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 + 6% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' +
			Rock or other impervious formations	none

Lot Area 17,000 Sq'



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 700 Linear Ft. 300
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Pfass + Sales

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-14-98

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold