IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Forti's corp DATE 7-14-98 PERMIT NO.

PHONE: Business Home

LOCATION 21 N TR on Rd 2171 TL on Rd 2172

SUBDIVISION NAME Danbury Forest LOT NO. 18 SECTION OR BLOCK NO. S. R. No.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 17,000 Sq'

Character & Porosity of Soil LSBz
Percolation Rate 120 min/inch
Topography 2 to 6% slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Pfass Sale

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-14-98

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold