DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

4747-03-5208

Sheet 1 of 1
PROPERTY ID #:
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: BOYCE KNOX — APPLICATION DATE:
ADDRESS: 222 INGRAM RD 28625 — DATE EVALUATED:
PROPOSED FACILITY: 3BR — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: 1
LOCATION OF SITE: US 21N (TL) SHUMAKER TL INGRAM ~1 MILE ON — PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other RIGHT WHITE HSE BESIDE LG BARN
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut — TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	L	0-7	GR SL	VFR NS/NP SxP	—	>48"	—	—	PS 0.30
		7-38	SBK C	FR S/P "					
		38-48	SBK C+SAP	FR S/P "					
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		PS
System Type(s)		II
Site LTAR		0.3

OTHER FACTORS (.1946): NO
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: CS
OTHER(S) PRESENT: BOYCE KNOX'S FATHER

COMMENTS: