DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Tommy Hall CABLE / AGENT: _____ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: Single Family Dwelling
PROPERTY SIZE: 1.0 acre
LOCATION OF SITE: Lot 14 / Greystone meadows
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring / Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(2) TEXTURE	.1941 (a)(3) STRUCTURE	.1941 (a)(4) CONSISTENCE	
1	Linear 2 to 4%	0 to 2	L	GR		.1942 WETNESS CONDITION - N/A
		2 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		36 to 48	C	weak Blocky	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .38
2	Linear 2 to 4%	0 to 4	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 42	C	SBK	1:1	.1943/.1956 SAPROLITE - Transition
		42 to 48	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .38
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .38
OTHER FACTORS(.1946) _____ SYSTEM TYPE: Conv. Gravity
EVALUATED BY: R. C. Moore OTHER(S) PRESENT: Banks Brown Darrit Young
COMMENTS: _____

DRAFT