10004

34022

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dan Dalton DATE 11/28/89 PERMIT NO. A-11

PHONE: Business _____ Home _____

LOCATION _____

SUBDIVISION NAME Cornerstone LOT NO. 8 S. R. No. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit: Yes (✓) No ( )

Auto. Dishwasher: Yes (✓) No ( )

Auto. Wash. Machine: Yes (✓) No ( )

Site Suitable: Yes ( ) No ( )

Lot Area 1.3 acres

Character & Porosity of Soil Clayey


Percolation Rate 35 min/inch

Topography 3-5%

Depth to Water Table 40"+

Rock or other impervious formations None noted

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1250+ Linear Ft. 450+

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Excellent Work!

CERTIFICATE OF COMPLETION BY _____ DATE 11/28/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold