PAGE 01
IREDELL ENVHLTH STVL
7848713483
05/22/2009 14:42

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14746S PIN# 4747329846

OWNER OR APPLICANT KW Nicholson Inc PHONE Business 704 902 0799 Home DATE 1-28-08

ADDRESS 166 Doe Run Trl

LOCATION 21 N, (L), on Shoemaker Dr., Turn into Wildes Farm Road (L) on Doe Run, Lot on left

SUBDIVISION Greystone Meadow BLOCK / SECTION LOT 38 LOT AREA 145x300 SITE CLASS PS DESIGN FLOW 480 L.T.A.R 3

Septic Tank 1000 Gallons: STB 1012 Date 10-3-07
Pump Tank Gallons: PT Date
Pump Make Model Serial No
Notification Field No Fields 1 Square Feet 1600 Linear Feet 400
No Lines 5 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI
System Description: 25% Reduction Gravity
Repair System Description: 25% Reduction (pump if nec)
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No Bedrooms 4 No. Persons No Employees

Water Supply: ☐ Individual ☒ Public ☐ Community

☒ Gravity ☐ Pressure ☒ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing


Comments/Conditions
(5) 3' x 80'

Comments/Conditions

The proposed / ~~existing~~ SWIMMING POOL addition does not appear to impact the existing septic system.
**NOTE:

R. STEVE HEDRICK REHS
Date: AUG 9, 2010
ICHD-Environmental Health Division

INITIAL SITE SKETCH



Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed date 1-29-08
Improvement Permit by date 1-28-08
Authorization to Construct by date 1-28-08

Installed by
Operation Permit by date 7-2-08
Existing System Inspection by date

HEALTH DEPT COPY WHITE OWNER COPY (FINAL) YELLOW OWNER COPY (INITIAL) PINK