HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Gary Hawks OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 6-23-94
PROPOSED FACILITY: Single Family Dwelling
PROPERTY SIZE:
LOCATION OF SITE: lot 17 Grey ~~Rock~~ Stone meadows
WATER SUPPLY: On-Site Well Comm. Well Public / Other EVAL. METHOD: Auger Boring / Pit Cut

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	LS 10 to 15%	0 to 4	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE - PS
		36 to 48	Transition			.1944 RESTRICTIVE HORIZON - PS
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	LS 8 to 10%	0 to 6	L	GR		.1942 WETNESS CONDITION - N/A
		6 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE - PS
		36 to 48	Transition			.1944 RESTRICTIVE HORIZON - PS
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3	LS 12 to 14%	0 to 6	L	GR		.1942 WETNESS CONDITION - N/A
		6 to 24	C	SBK	1:1	.1943/.1956 SAPROLITE - PS
		24 to 36	Transition			.1944 RESTRICTIVE HORIZON - PS
		36"	saprolite			.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) SYSTEM TYPE Conv. Gravity
EVALUATED BY: P.C. Moore OTHER(S) PRESENT: Kent Nicholson (Builder)
COMMENTS:

DRAFT