I

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Paul Kearns DATE 7-24-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION White Fm Rd

S. R. No. _____

SUBDIVISION NAME Graystone meadows LOT NO. 19+20 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Horse Barn

No. Bedrooms _____ No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area 2.3 acres

Character & Porosity of Soil Clayey


Percolation Rate 14

Topography 2 to 6%

Depth to Water Table 10'+

Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 450 Linear Ft. 150

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (1)

Installed by A-1 Backhoe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 7-24-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold