DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 4747399490
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dixieland
ADDRESS: 133 Redemption Road
PROPOSED FACILITY: 3BR
LOCATION OF SITE: _____
WATER SUPPLY: • Private • X Public • Well • Spring • Other _____
EVALUATION METHOD: • Auger Boring • X Pit • Cut

APPLICATION DATE 9/30/13
PROPOSED DESIGN FLOW (.1949): 360
DATE EVALUATED: 10-3/13
PROPERTY SIZE: .6569
PROPERTY RECORDED: yes
TYPE OF WASTEWATER: • X Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 10	0-21	C SBK	ss sp	n/a	48"	n/a	n/a	.3 PS
		21-48	CL SBK	ss sp					
2	LS 10	0-20	C SBK	ss sp	n/a	48"	n/a	n/a	.3 PS
		20-48	CL SBK	ss sp					
3	LS 10	0-23	C SBK	ss sp	n/a	48"	n/a	n/a	.3 PS
		23-48	CL SBK	ss sp					
4	LS 10	0-21	C SBK	ss sp	n/a	48"	n/a	n/a	.3 PS
		21-46	CL SBK	ss sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	II	III
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: James Stewart
OTHER(S) PRESENT: none

COMMENTS: _____