1462

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roy B. Cline DATE 5-18-90 PERMIT NO. 161-0-10

Home Business Phone

LOCATION Wilkes Farm Rd Turn on Dietz Rd
1/4 mile on Rt

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Clay loam
Percolation Rate 45 min/inch
Topography Level
Depth to Water Table
Rock or other Impervious Formations None

Lot Area 125'x225'

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Plot of System

Size of Tank 1000 Gals.
Number of Bedrooms Facility: 4
No. of Units
Sq. Ft. Lateral Area Req'd. 300
Depth of Soil to Limit 72"
Water Supply: Individual ( )
Public (✓)

Installed by B-I Backhoe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 5-24-90

EXISTING SYSTEM CHECKED BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making application for Permit.

Health Dept. Copy: White Inspections Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

JAN. 4, 1989 6:17