35787

IREDELL COUNTY HEALTH DEPARTMENT

10717 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR KERNS & LEVAN DATE 1/27/90 PERMIT NO. 10F-S-A-7

PHONE: Business _____ Home _____

LOCATION US 21 N TL SHUMAKER → WHITE'S FARM RD TL GREYSTONE
1ST HOUSE ON (R) S. R. No. _____


SUBDIVISION NAME GREYSTONE LOT NO. 17 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2 1/2
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1 AC

Character & Porosity of Soil SANDY CLAY LOAM
Percolation Rate 3
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations NONE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 260 Linear Ft. 320
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by JAMES HUDDLER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. MOORE

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HENRICK / KELLY SHEEKS DATE 2/12/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold