DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of _____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: John & Lelbang 873-7885 APPLICANT: John Moorefield
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 4/20/01
PROPOSED FACILITY: 3BR Home PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .53A.
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Subdivision Lot #39

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	8% Linear	0-8	0-8 Scr fine	SS SP SEXP					PS .35
		8-24	8-24 scr many fine	SP SFI					
		24-38	24-35 scr many fine 35-38 sapr	SS SP SEXP					
		38-48	38-48 sapr	NS VP NEXP					
2	7% Linear	0-3	0-3 Scr very fine	FI SS SP SEXP					PS .35
		3-23	3-23 scr many fine	FI SP SEXP					
		23-30	23-30 scr many fine	FI SS SP SEXP					
		30-48	30-48 sapr	NS VP NEXP					
3	Linear 5%	0-7	0-7 sc	FI NS VP NEXP					PS .3
		7-10	7-10 scr many fine	FI SS SP SEXP					
		10-29	10-29 scr many fine	FI SP SEXP					
		29-44	29-44 scr many fine	FI SS SP SEXP					
		44-48	44-48 sapr	NS VP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity Conventional	Pump 25% Red.
Site LTAR	.35	.30

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____