IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

LAXTON CONST. CO.

OWNER OR CONTRACTOR Southern Bell DATE 4-19-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N - to Jenning Rd # 1883 - Go Approx 2 mile to Rd # 1913 on Left. Bldg. on S/W Corner S. R. No. 1882

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other _____

No. Bedrooms _____ No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area 1.5 ACRES


Character & Porosity of Soil Cecil Clay

Percolation Rate Fair

Topography 2-6% Slope

Depth to Water Table —

Rock or other impervious formations —



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY [signature]

COMMENTS: Flexible Plastic Pipe from tank to distribution box

CERTIFICATE OF COMPLETION BY [signature] DATE 4/19/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold