DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kay McMillian APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: 2-16-01 DATE EVALUATED: 3/2/01
PROPOSED FACILITY: 3 PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .53
LOCATION OF SITE: 38R House Creek PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut 300 - 2
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed 251 - 300
Lot #36

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	6% Linear	0-9	SL	VFR NP VFP					PS .35
		9-19	cl fsl mod sbk	SS SP SE P					
		19-26	scl mod f sbk	SS SP ✓					
		26-48	scl f cpt ✓	SS SP ✓					
2	6% Linear	0-6	SL sgr	NS NP NE P					PS .35
		6-18	scl mod f sbk	SS SP SE P					
		18-32	cl Heavy mod f sbk	SS SP SE P					
		32-36	vcl f cpt ✓	S P ✓					
		36-48	Sap f cpt						
3	6% Linear	0-4	SL	NS NP NE P					PS .35
		4-18	scl mod f sbk	SS SP SE P					
		18-26	cl H f sbk	✓ ✓ ✓					
		26-48	scl H, f cpt Sap	✓ ✓ ✓					
		(#1)							
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Standard Conv	25% Reduction Conv
Site LTAR	.35	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Jackson
OTHER(S) PRESENT: _____