DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jeff Jones APPLICATION DATE 1st July 09
ADDRESS: _____ DATE EVALUATED: 16 July 09
PROPOSED FACILITY: 3 BR Home PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Dawsdale Dr. Stallion Ridge PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 12%	0-28	SBK/C	F/SmP	>48	>48	–	–	PS 0.3
		28-48	cBK/C1	F/SmP					
2	L 12%	0-26	SBK/C	F/SmP	>48	>48	–		PS 0.3
		26-48	cBK/C1	F/SmP					
3	L 12%	0-29	SBK/C	F/SmP	>48	>48	–	–	PS 0.3
		29-48	cBK/C1	F/SmP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Ps	Ps
System Type(s)	25%	25%
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: TCH
OTHER(S) PRESENT: _____

COMMENTS: _____