DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: R+L Constructors APPLICANT: David R Wilson
ADDRESS: _____ APPLICATION DATE: 3-5-a DATE EVALUATED: 3/14
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~54
LOCATION OF SITE: _____ PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed Saddlewood Lot #7

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	2% Linear	0-4	Sl g	NS NP VFr					PS .35
		4-24	cl many/mica WSBk	SS P VFr					
		24-36	Cl Many/mica	SS P Sl					
		36-38	Sap cl (g)						
2	5% Linear	0-9	Sl g	NS NP VFr					PS .35
		9-21	cl many mica	SS SP					
		21-38	cl many mica Sap	SS SP SFr					
		38-48	Sap u/cl (g)						
3	3% Linear	0-9	Sl	NS NP VFr					PS .3
		9-12	Scl usbk	SS SP SFr					
		12-36	cl some msbk mica	SS SP SFr					
		36-48	cl many mica/Sap (g)						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity Conventional	25% Reduction Pump
Site LTAR	.35	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Billy Johnson
OTHER(S) PRESENT: _____