IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 181068

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4747652319

APPLICANT: Hendricks Builders APPLICANT ADDRESS: 346 New Sterling Rd

SITE ADDRESS: 135 Stallion Lane Statesville, NC 28625 PHONE: 704 462 3933 ALT. PHONE:

SITE DIRECTIONS: 21N, (L) Shumaker Drive/Whites Farm Rd (R) Donsdale, (L) Stallion Ln site at end of cul-de-sac.

SUBDIVISION: Donsdale SECTION: LOT # 20 LOT AREA: .936 DESIGN FLOW: 480 L.T.A.R.: .3

Septic Tank	1000 (gal)	STB	1012	Date	5-9-14	☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI	☒ Residence	No. Bedrooms	4
Pump Tank	N/A (gal)	PT	N/A	Date	N/A	System Description: 25% Reduction Gravity	☐ Business	No. Persons	
Pump Make	N/A	Model	Tuffaite	Serial #	EF-4	Repair System Description: 25% Reduction Pump	☐ Other	No. Employees	
# Nitrification Fields	1	# Lines	4	Linear Ft:	400	Maintenance Agreement Required: ☐ YES ☒ NO	☐ Slab	☒ Crawl Space	
Trench Width	36"	Max. Trench Bottom Depth	36"	Gravel Depth	N/A	☒ GRAVITY ☐ PRESSURE	☐ Basement w/plumbing	☐ Basement w/o plumbing	

Water Supply: ☐ Private ☒ Public ☐ Community

Comments / Conditions:

INITIAL SITE SKETCH

AS BUILT SKETCH

see attached system design by Patrick L. Mitchell, LSS

Installed Quick 4 as drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Martin Hendricks Date: 9-24-13 Installed by: Tommy Fry

IMPROVEMENT PERMIT by: Date: 9-20-13 OPERATION PERMIT by: Date: 06/23/14

AUTHORIZATION TO CONSTRUCT by: Date: 9-23-13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK