HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: William Houpe OWNER: AGENT: PHONE: 876-2323
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	Linear 6 to 8%	No Topsoil				.1942 WETNESS CONDITION -	N/A
		0 to 48	C	5BK	1:1	.1943/.1956 SAPROLITE -	N/A
						.1944 RESTRICTIVE HORIZON -	N/A
						.1945 PROFILE CLASSIFICATION -	PS
						PROFILE LTAR -	.35
2	Linear 6 to 8%	No Topsoil				.1942 WETNESS CONDITION -	N/A
		0 to 48	C	5BK	1:1	.1943/.1956 SAPROLITE -	N/A
						.1944 RESTRICTIVE HORIZON -	N/A
						.1945 PROFILE CLASSIFICATION -	PS
						PROFILE LTAR -	.35
3						.1942 WETNESS CONDITION -	
						.1943/.1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1945 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	
4						.1942 WETNESS CONDITION -	
						.1943/.1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1945 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	
5						.1942 WETNESS CONDITION -	
						.1943/.1956 SAPROLITE -	
						.1944 RESTRICTIVE HORIZON -	
						.1945 PROFILE CLASSIFICATION -	
						PROFILE LTAR -	

AVAILABLE SPACE (.1945) _____ SITE CLASSIFICATION (.1948): yes SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) _____ SYSTEM TYPE conv. Gravity
EVALUATED BY: L.C. moore OTHER(S) PRESENT: _____
COMMENTS: _____

DRAFT