IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bonnie Tomlin DATE Sept. 23, 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 2.1 N, T.L. on Jennings Rd., cross I-77 bridge, T.R. at church on dirt drive, house on left S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	sandy loam	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	none	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	slope to rear	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none	
			Rock or other impervious formations	none observed	

Lot Area _____



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: System 50 ft. from well

CERTIFICATE OF COMPLETION BY Charles G. Gardner + Andrew E. Causey DATE Sept. 23, 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold