IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

Steve Swaltney

OWNER OR CONTRACTOR Tarheel Textile Inc. DATE 13 Dec 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N. to Jennings Rd. Cross I-77 1st driveway on left.

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Industry - approx - 40 employees

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area _____


Character & Porosity of Soil Red Clay

Percolation Rate none

Topography Slope to rear of bldg

Depth to Water Table 10'

Rock or other impervious formations 10'



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 6

Sq. Ft. 1800 Linear Ft. 600

Depth of Stone in Lines 14"

Water Supply: Individual (✓)

Public ( )

Installed by Parker Looky

IMPROVEMENTS PERMIT BY _____

COMMENTS: 5" line used on top joint

CERTIFICATE OF COMPLETION BY Will Howell DATE 13 Dec 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold