IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Davidson DATE 20 Sept 74 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 21 N to Jennings Rd. to area L-77 - 1st Driveway on right after crossing bridge beside Church. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 4 acres

Character & Porosity of Soil Red Clay Loam
Percolation Rate none
Topography Slope to end of home
Depth to Water Table unk
Rock or other impervious formations unk



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: off Jennings Rd approx 3/8 mi

CERTIFICATE OF COMPLETION BY [illegible] DATE 20 Sept 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold