DEPARTMENT OF ENVIRONMENTAL HEALTH
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 104778
COUNTY: 4747-81-9097

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: RICHARD SIMMONS WELL APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: 21N, ⓒ JENNINGS, 3RD BUS on LEFT PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut ⑤ SAME AS HOLE #4
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed ⑥ ~~HOLE~~ SAME AS HOLE #4

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	4% L	0-40 40-	Compacted Fill NATURAL			FILL	DIRT/compaction		US
2	4% L	0-30 30-	Compacted Fill NATURAL		compacted 30"				US
3	4% L	0-28 28-60"	cl brown sbk C, med abk	fr s p fr s sp, slep	water seepage in pit FRENCH DRAIN				.25
4	30% SW CV	0-6 6-32" 32-48"	scl, wk, gr C, med, sbk Sep mix C, med, sbk	fr, ns, np, mcp fr, s, p, slep fr ss, sp, slep		748"			PS .3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____