IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Elizabeth Rucker DATE 11-1-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N - TL on Jennings Rd. TL on Rd # 1941 Mobile Home at end of Rd. S. R. No. 1941


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	LMBr	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	mod	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 - 6% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none	
			Rock or other impervious formations	none	

Lot Area _____



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 250 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Eddie Gentry & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Fox DATE 11/1/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold