DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: 4747-89-0102
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: BUTTERNUBBER BUILDERS APPLICANT: RICK ODUM
ADDRESS: 749 BLACKWELDER RD, STATESVILLE APPLICATION DATE: 1-9-02 DATE EVALUATED: 2-5-02
PROPOSED FACILITY: 3BR H/C PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 142 x 390'
LOCATION OF SITE: JEANNETTE RD, TO BLACKWELDER RD, 0.10 MILES ON R PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	SLIGHT H 3%	0-48	SBK C	FR SS/SP SSAP					PS 0.25
2	SLIGHT H 4%	0-48	SBK C	FR SS/SP SSAP					PS 0.25
3	SLIGHT H 4%	0-48	SBK C	FR SS/SP SSAP					PS 0.25
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: RICK ODUM