IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ray Love DATE 12/22/82 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N, Lt on Jennings, Rt on Blackwelder, Log House 3/4 mile on Rt S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes ( ) No (✓)

Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clayey

Percolation Rate 04 spd/ft


Topography 2-6%

Depth to Water Table 10'+

Rock or other impervious formations None

Lot Area 8 acres

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 350 Linear Ft. 450

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Paul Frye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: Paul installed 450 Lf instead of 300 as permitted. OK by ICS.

CERTIFICATE OF COMPLETION BY [signature] DATE 12/22/82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold