DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Alan Lewis OWNER: ✓ AGENT: ___ PHONE: 878-2305
ADDRESS: Rt 4 Box 202-7 Sta APPLICATION DATE: ___ DATE EVALUATED: 8
PROPOSED FACILITY: Single Family Dwelling
PROPERTY SIZE: 110' x 200'
LOCATION OF SITE: 7 N Th Jennings Rd / TR Amberlite 1/4 mi on Rt
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___
Lot 31 Amberlite

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Linear Slope 2 to 8%	2"to 6"	Gr L	1:1 Fr.	N/A	N/A	PS	N/A	.35
		6 to 48	SBK CL	1:1 Fi					
2	Linear Slope 2 to	2" to 6"	Gr L	1:1	N/A	N/A	PS	N/A	.35
		6 to 48	SBK CL	1:1					
3									
4									
5									

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
EVALUATED BY: B C moore OTHER(S) PRESENT: Alan Lewis
COMMENTS: ___