DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jack Borders OWNER: _ AGENT: _ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6-9-95
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 7 Amhelsite
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other_____ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINERALOGY	
1	Linear	0 to 4	L			1942 WETNESS CONDITION - N/A
		4 to 48	C	SBK	1:1	1943/ 1956 SAPROLITE - N/A
						1944 RESTRICTIVE HORIZON - N/A
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	Linear	0 to 4	L			1942 WETNESS CONDITION - N/A
		4 to 48	C	SBK	1:1	1943/ 1956 SAPROLITE - N/A
						1944 RESTRICTIVE HORIZON - N/A
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3						1942 WETNESS CONDITION -
						1943/ 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						1942 WETNESS CONDITION -
						1943/ 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						1942 WETNESS CONDITION -
						1943/ 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Y/N/A SITE CLASSIFICATION (.1948) PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) _____ SYSTEM TYPE Cow Gravity
EVALUATED BY: RC Woods OTHER(S) PRESENT Jack Borders
COMMENTS: _____

DRAFT