DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dixieland APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 7-9-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 360gpd PROPERTY SIZE: ___
LOCATION OF SITE: Lot 59 Deer Crossing PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	1-12% S/L	0-5	wk sbk LoamySand	loose sso					.3
		5-30	mfsbk RC	frssso/SSP					
		30-48	wk-fsbk RCl	frssso common infSAP					
		48-60	massive LSAP	frssso					
2		0-3	wk fsbk RCl SCL	frssso			PS 2814		.3
		3-25	wk-mfsbk RCl/CL	frssso SSP					
		25-59	massive pbwL SAP	frsso					
3	9%	0-25	mfsbk RCl/C	frssso SSP					-3
		25-44	wk fsbk RCl/L SAP	frssso Gravelly L					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	SCRD 25% Red	LPP 25-50%
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DM
OTHER(S) PRESENT: Angie Lord