DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dixieland Inc APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 1-8-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 4 Bdrm PROPERTY SIZE: _____
LOCATION OF SITE: Lot 25 Deer Crossing PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	8% ± L	0-6	g-wk fsbk brn-R brn sl fr sss p						.3
		6-27	m fsbk RC	fi SO SSPO					
		27-40	wk-m fsbk RCL	fr SS SO SSPO					
		40-57	wk fsbk transition to mass LSPO	vfr LSPO fr SS SP					
2	8% L	0-2	gr brn sl fsbk	fr SS SP					.25-.3
		2-21	m fsbk RC	fi SO SSPO					
		21-60	wk fsbk-mass LSPO	fr SPO fr SS P					
				fr SS P to mod SS*					
3	8% L	0-8	wk-m fsbk brn-R brn cl	fr SS P					.25
		8-22	wk fsbk RC	fi SO SSPO					
		22-48	(ac) wk fsbk mass	fr SS P SSPO common vfi SPO 36%					
		48-60	mass LSPO	fr SS SP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	LP PPBPS	LP PPBPS
Site LTAR	.25-.3	.25-.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: JP Hinson, RS
OTHER(S) PRESENT: _____