DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dixieland
APPLICANT: ___
ADDRESS: ___
APPLICATION DATE: ___
DATE EVALUATED: 3-31-05
PROPOSED FACILITY: ___
PROPOSED DESIGN FLOW (.1949): 360gpd
PROPERTY SIZE: ___
LOCATION OF SITE: Lot 81 Deer Crossing
PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	7-10%	0-3	wkSBK fri sdl	frssp					-3
		3-25	mfSBK RC	frssspSDxp					
		25-56	wkSBK yR cl	frssspSDxp mic/sap					
2		0-3	wkSBK fri sdl	frssp					-3
		3-24	SBK RC	frssspSDxp					
		24-57	wkSBK yR cl	frssspSDxp few common mic/sap					
3		0-7	wkSBK fri sdl	frssp					-3
		7-32	mfABK/SBK RC	frsp/ssspSDxp					
		32-56	wkSBK RCl	frssspSDxp common mic/sap					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv PPBS	Conv Pumped PPBS
Size (.1949)	03	03

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DH
OTHER(S) PRESENT: Sandy McDuffie