DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

OWNER: Dixieland
APPLICATION DATE: ___
ADDRESS: ___
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 360 gpd
DATE EVALUATED: 11-25-03
LOCATION OF SITE: Lot 17 pha 3 Deerlanding
PROPERTY SIZE: ___
PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed House Site not staked 11-25-03

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	9% S/L	0-8	S/compacted BSCL	fr: SSSP					.3
		8-27	WMFSBK RC	fr: S/SP SSAP					
		27-47	WFSBK YRCL	fr: SSSP - few SAP					
		47-70	Mass OLV/BSLSAP						
2	9% S/L	0-6	WSBK BSCL	fr: SSSP SSAP					.25
		6-37	RC ABK	fr: SP SSAP - few YB's					
		37-70	MFSBK LCL	fr: SSSP - common SAP					
3		0-3	WSBK BSCL	fr: SSSP SSAP					PS .3
		3-17	MFSBK RBK/C	fr: SSSP SSAP					
		17-44	WFSBK RBCL	fr: SSSP - common mica/ferruginous SAP					
		44-68	M OLV/BFSL						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv 25% Red.	LPP/BBS
Site LTAR	.025-.3	.25-.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [signature] Brad Thomas
OTHER(S) PRESENT: ___

COMMENTS: ___