EDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

MIT# 120074 PIN# 4748 30 2716 DATE July 15, 05

IER OR CONTRACTOR Dixieland Inc. PHONE: Business Home

RESS 823 Jennings Rd, Statesville, N.C. 28625

ATION US 21 N. TL Jennings Rd. TL Deer Haven TR Sundance Cir. on Right

DIVISION Deer Crossing BLOCK / SECTION LOT 69 LOT AREA .590 Ac SITE CLASS. PS DESIGN FLOW 360gpd L.T.A.R. .3

tic Tank: 1000 Gallons: STB 8625 Date 8-30-05

np Tank: Gallons; PT Date

np Make: Model Serial No.

ification Field: No Fields 1 Square Feet 900 Linear Feet 300

Lines 5@60' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: Gravity 25% Red. "Accepted"

Repair System Description: pm 25% Reduction

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☐ Other

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☐ Community

ments:/Conditions:


Comments:/Conditions:

Blue Sniffer tube filter.

Septic tank TRASH CATCH Installed

1" = 50'

INITIAL SITE SKETCH



The proposed Building/Patio addition does not appear to impact the existing septic system.

**NOTE:

Kelly Cook R.S.

Date: 4-23-09

ICHD-Environmental Health Division

mit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement mit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

ned: Richard Mott date 7-20-05 Installed by: Rowan Septic

rovement Permit by: date 7-15-05 Operation Permit by: Kelly Cook date 10-12-05

horization to Construct by: date 7-15-05 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK