DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dixieland Inc APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-11-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 360gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 69 Deer Crossing PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	S-V 6%	0-7	gr wksck tan-brn sl/scl fi gr sbsp						.3
		7-49	wk rck rel/cl	lpkso-sssosbkp fam	common		w/rock		
2	S-V 6%	0-8	vermiculated sil/c fi-vf						.3
		8-35	wk fsbk rc	frsosbkp					
		35-46 (BC)	wk fsbk yr-rc	frssbkp	few/ver low		rock		
3	S-V 6%	0-10	gr brn sl/scl fr sssbp						.3
		10-29	wk msbk cl/cl	fr sssbp stkp					
		29-48 (BC)	wk fsbk yr-rc	fr/fi sssbp common stkp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	85	85
System Type(s)	Gravel Bed	Pumped Gravel Bed
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): 85
EVALUATED BY: DRH
OTHER(S) PRESENT: _____