DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dixieland APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-11-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): ~~400 Bdpd~~ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 70 Deer Crossing PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	S-L 5-6%	0-6	gr-wk sbk fsl	sl sst fi sssp					.3
		6-23	mst blky rc	fr sp sspl					
		23-50	wk sbk rcl	fr sss sp few common mi sap					
2	R L 2%	0-6	vmst sbk chsl	fi sss p					.3
		6-20	wk sbk rc	fr sss p sap					
		20-48	(Bc) wk sbk vpc L	fr sss p few common mi sap					
3	R-S 2%	0-4	gr-wk sbk chsl	fi fr sss p					.3
		4-27	wk sbk RC	fr sl sss p sap					
		27-40	(Bc) wk sbk RC	fr sss p common mi sap					
		40-54	Massive (BCr) vwk sbk L/scl	fr sss p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	PM 25% Red.	PM 25% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): B
EVALUATED BY: DH Hussin
OTHER(S) PRESENT: _____