IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

1300 T.G.J

PERMIT# 120076 PIN# 4747-39-1486.91 4748-30-4790 DATE May 28, 04

OWNER OR CONTRACTOR Ashland Inc. PHONE: Business Home

ADDRESS 823 Jennings Rd. Statesville, N.C. 28625

LOCATION 21 N. TL Jennings Rd. TL Deer Haven TR Swallowe Circle on Right

SUBDIVISION Deer Crossing BLOCK / SECTION LOT 71 LOT AREA .913 Ac SITE CLASS PS DESIGN FLOW 480 gpd L.T.A.R. .83

Septic Tank: 1000 Gallons; STB 825 Date 4-2-05

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 5 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair System Type: I. II. III. IV. V.

System Description: * Gravity 25% Reduction

Repair System Description: pumped conventional

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms 2.5

☐ Business No. Employees

☐ Other

☑ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing


Water Supply: ☐ Individual ☑ Public ☐ Community

Comments/Conditions:

* House site must not be cut/lowered in order to do gravity.

1"=50'

INITIAL SITE SKETCH



Comments/Conditions:

SEPTIC TANK WITH MARKER INSTALLED USING "Polylok" FILTER

The proposed / existing Accessory Building addition does not appear to impact the existing septic system.

**NOTE:

REHS

Date: 6-24-10

ICHD-Environmental Health Division

SYSTEM INSTALLED ACCORDING TO INITIAL SITE SKETCH USING 100 "QUICK-4 INFILTRATOR" CHAMBERS

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 6/3/04

Improvement Permit by: [signature] date 5-28-04

Authorization to Construct by: STEVE HENDRICK date 3-29-05

Installed by: ROWAN SEPTIC

Operation Permit by: STEVE HENDRICK date 5-19-05

Existing System Inspection by: date

HEALTH DEPT COPY: WHITE OWNER COPY (SIGN): YELLOW

IREDELL ENHLTH STVL PAGE 01
06/29/2005 15:57 7048713483