DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

OWNER: Dixieland Inc APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: 11-25-03
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 14 Pha 3 Deer Crossing PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-3	gr fsm sL	fr			95"+ PS		.3
		3-45	mfsbk rcl L	fr sss p so/p					
		45-60	wk fsbk-massive yr	L sth fr sss p					
2		0-8	yr fsm sl	fr sss p so/p					.3
		8-30	sbk rc	fr fr sss p					
		30-55	wk fsbk rcl	fr sss p	sl/p common mod sola w. rock				
3	8-12% L	0-40	wk m fsbk rc (wpng @ compaction)	fr sp so/p					.25 < 40"
		40-67	wk fsbk yr rbmcl	fr sss p	common sl/p.	mod w. rock			
4		0-17	C fill						.25 4 ft to fill
		17-27	Somewhat compacted brn sl	fi sss p					
		27-61	sbk rc	fi sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	BS	BS
System Type(s)	CONV PPBDC	LPP BDS
Site LTAR	.3	.25-.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____