HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 10L-A-11
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: CARL HEDRICK OWNER: ✓ AGENT: PHONE: 876-0095
ADDRESS: Rt. 5, Box 98-A APPLICATION DATE: 9/9/93 DATE EVALUATED: 9/9/93
SVL, NC 28677 PROPOSED FACILITY: SD/W MH 3BR
PROPERTY SIZE: 66 ACRES
LOCATION OF SITE: 4S 21 N, TL JENNINGS ROAD, MH ON (2) ~ 2000' BEFORE RIVER (S. YADKIN)
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	N 6-8%	0-20	C	ABK	1:1 / FI	.1942 WETNES CONDITION S -
		20-48	SC	WSBK	1:1 / FI	.1943/.1956 SAPROLITE S - MIXED @ 20"
						.1944 RESTRICTIVE HORIZON S -
						.1948 PROFILE CLASSIFICATION PS -
						PROFILE LTAR 0.35 GPD/FT²
2	L 6-8%	0-24	C	ABK	1:1 / FI	.1942 WETNES CONDITION S -
		24-48	C	WSBK	1:1 / FI	.1943/.1956 SAPROLITE S - MIXED @ 24"
						.1944 RESTRICTIVE HORIZON S -
						.1948 PROFILE CLASSIFICATION PS -
						PROFILE LTAR 0.35 GPD/FT²
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: MRS. CARL HEDRICK
COMMENTS:

DRAFT