SHEET 1 OF 1

DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: 13D-D1
DATE: 3/17/95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: RUTH PITMAN
OWNER ✓ AGENT: PHONE: 873-6751
ADDRESS: 122 ROCKHAVEN DR STVL, NC 28677
APPLICATION DATE: 3/12/95 DATE EVALUATED 3/17/95
PROPOSED FACILITY: 2 BR / BATH
PROPERTY SIZE: 90' x 150' LOT

LOCATION OF SITE: IVEY & OAKS MHP #8
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (*)(1) TEXTURE	.1941 (*)(2) STRUCTURE	.1941 (*)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	L	0-12	SC	SBK	1:1 / FI			.1942 Wetness Cond. S
	20%	12-48	S/SL	SAPROLITE	ACIDIC 1:1			.1943 Depth/.1956 Sapr. PS
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.4
2	N	0-12	SC	SBK	1:1 / FI			.1942 Wetness Cond. S
	22%	12-48	S/SL	SAPROLITE	ACIDIC			.1943 Depth/.1956 Sapr. PS
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.4
3	L	0-14	SC	SBK	1:1 / FI			.1942 Wetness Cond. S
	22%	14-48	S/SL	SAPROLITE	ACIDIC			.1943 Depth/.1956 Sapr. PS
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.4
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS

SYSTEM TYPE CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.4 GPD/FT²

EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: RUDI PITMAN

COMMENTS:

00494