33390 M. J. Ayton

9665 IREDELL COUNTY HEALTH DEPARTMENT 13D-A-8

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Johnson DATE 9-19-89 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd 3/10 mi Past Yadkin R. TL on L drive back off Road S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ✓ Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Prev. Suitable
Percolation Rate 2+ to 120
Topography 2+
Depth to Water Table 10+
Rock or other impervious formations Scattered Rock


Lot Area 8.9 acres

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)



Plot of System

Installed by A-1 backhoe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY D. weaver

COMMENTS: _____

CERTIFICATE OF COMPLETION BY ✓ D. C. moore DATE 9-19-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold