IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Phil Hagel DATE June 28, '78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd. N. x South Yadkin River ½ mi. on left

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Red clay loam


Percolation Rate —

Topography 6-10%

Depth to Water Table unk.

Rock or other impervious formations none obs.

Lot Area acreage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 750 Linear Ft. 250

Depth of Stone in Lines 10" +

Water Supply: Individual (✓)

Public ( )

Installed by Sam Osteralt

IMPROVEMENTS PERMIT BY D. R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE June 28, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold