DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____ of ____
COUNTY: Franklin

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Lon Root APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 6-5-2000
PROPOSED FACILITY: 4 Bd Rm PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: 11Ac
LOCATION OF SITE: ____ PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	PT (L) 8-10%	0-6	SAB	CL Rocky				33"	PS @ 21" -3
		6-33	SAB	C W/ Rock outcrop					
		33-36	Wth Rck						
		36+	SAP						
2	PT L 8-10	0-5	SAB	CL Rocky				33"(+-)	PS @ 21" -3
		5-33	SAB	C W/ Rock outcrop					
		33-38	Wth Rock						
		38+	SAP						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	↘	↘
System Type(s)	Conv Gravity	Same
Site LTAR	-3	-3

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: JC Pettigo & Faye C. Thompson
OTHER(S) PRESENT: ____