IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rex Bell DATE Feb 1, 1978 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd N. T.L. on Snow Creek Rd. (#1904) Go ~½ mi. in front of 1st chicken house on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Cecil loam
Percolation Rate —
Topography 2%
Depth to Water Table unk
Rock or other impervious formations moreels

Lot Area acreage



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"+
Water Supply: Individual (✓)
Public ( )

Installed by Hicks Bros

IMPROVEMENTS PERMIT BY C R Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Clark R. Hinson DATE Feb 1, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold