IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Henderson DATE 8/18/87 PERMIT NO.

PHONE: Business Home

LOCATION 21N, Lf on Jennings, Lf on Snow Creek, Brick Res on Rt 1/4 mile. S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home ( ) Business ( ) Other


No. Bedrooms Repair No. Bathrooms

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Character & Porosity of Soil
Percolation Rate
Topography EXISTG
Depth to Water Table
Rock or other impervious formations

Lot Area

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Size of Tank EXISTG Gals.
Nitrification Field:
No. of Lines 10
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 12" +
Water Supply: Individual (✓)
Public ( )

Installed by James Huddler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Glenn Fox Jr.

COMMENTS: James Huddler replaced corrugated line going to old system w/ schedule 40 PVC. Tied onto tank w/ new tee at my OK.

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 9/18/91

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold