09846

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR TODD PADGETT DATE 4-20-89 PERMIT NO. 76.

PHONE: Business _____ Home _____

LOCATION Jennings Rd. north 1-L. on Friendship 1-L. on Bustle Rd - cross creek 1-L. at cedar house - 10th down behind house S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Prev. Suitable.

Percolation Rate 3 Min./in.


Topography 2-6%

Depth to Water Table 10'+

Rock or other impervious formations none observed.

Lot Area Ample.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 720 Lineal Ft. 240

Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Jon Hartness

I understand and agree to install septic tank system as specified on this improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Dana Weaver

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-10-89.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold