IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Keith Somers DATE 11-21-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd. N. to Charles. Driveway on left in front of Heath Cudell Store. Home on Rt. at end of driveway S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 Ac.


Character & Porosity of Soil Cecil clayloam

Percolation Rate _____

Topography 2-6%

Depth to Water Table unk.

Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"+

Water Supply: Individual (✓)
Public ( )

Installed by Ray Lentz

IMPROVEMENTS PERMIT BY W. M. Howard

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE 11-21-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold