## IREDELL COUNTY HEALTH DEPARTMENT

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald R. Johnson DATE 26 Sept 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Leaving Mt N to Charlie T.C. on Friendship Ch. Rd. # 1896. Go appx ½ mi - T.L. on dirt Rt 2nd house on Left S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | Clay loam | |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | none | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | Hilly to Steep | |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | ok | |
| | | | Rock or other impervious formations | ok | |

Lot Area 1 4/5 acres




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 350
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hoke Looby

IMPROVEMENTS PERMIT BY _____

COMMENTS: Deep - mostly good soil - some bad soil in swales.

CERTIFICATE OF COMPLETION BY Ivan Howard DATE 26 Sept 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold