38175

11984

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR BRYAN K. MURRAY DATE 1/25/91 PERMIT NO. 136-1-A 21,22

PHONE: Business 873-0766 Home

LOCATION US21 N, TL JENNINGS, TL FRIENDSHIP, TL PRIVATE ROAD ~ ¼ MI TO LAST HOUSE ON (L) S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 40,000 FT²

Character & Porosity of Soil PS


Percolation Rate .4 GPD/FT²

Topography VARIABLE - 4-6% LS

Depth to Water Table >4'

Rock or other impervious formations NONE OBSERVED

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement ACP 11/23/91



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by A-1 BACKHOE

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEARICK

COMMENTS:

CERTIFICATE OF COMPLETION BY STEVE HEARICK DATE 1/25/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold