HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 136-1-A-19
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: JOHN E. PITTS OWNER ✓ AGENT: PHONE: 876-0351
ADDRESS: RT 5, BOX 118-B APPLICATION DATE: 1/25/99 DATE EVALUATED: 1/25/99
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR D/W MH
PROPERTY SIZE: 100' x 200'
LOCATION OF SITE: US 21 N TO JENNINGS, TL FRIENDSHIP, TL PRIVATE ROAD ~ 1/4 MILE
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	1941 (a)(1) TEXTURE	1941 (a)(2) STRUCTURE	1941 (a)(3) MINEROLOGY	
1	N 4%	0-26	C	ABK	1:1 / FI	1942 WETNESS CONDITION: S
		26-48	SC	SBK	1:1 / FR	1943/1956 SAPROLITE: S
			MIXED SAPROLITE			1944 RESTRICTIVE HORIZON: S
						1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.35 GPD/FT²
2	L 6%	0-30	C	ABK	1:1 / FI	1942 WETNESS CONDITION: S
		30-48	SC	SBK	1:1 / FR	1943/1956 SAPROLITE: S
			MIXED SAPROLITE			1944 RESTRICTIVE HORIZON: S
						1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.35 GPD/FT²
3						1942 WETNESS CONDITION: -
						1943/1956 SAPROLITE: -
						1944 RESTRICTIVE HORIZON: -
						1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
4						1942 WETNESS CONDITION: -
						1943/1956 SAPROLITE: -
						1944 RESTRICTIVE HORIZON: -
						1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
5						1942 WETNESS CONDITION: -
						1943/1956 SAPROLITE: -
						1944 RESTRICTIVE HORIZON: -
						1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -

AT END OF RD

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946): NONE SYSTEM TYPE: CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: JOHN E. PITTS
COMMENTS:

DRAFT